

# **Boylston Water District**

## **Commissioners Report for 2007**

### **Operations:**

During the year 2007, the District had a total of one thousand one hundred forty-five (1145) customers as of January 1, 2008.

A total of 186,441,934 gallons were pumped into the system, as recorded at the Pumping Stations located on Main St. and Scar Hill Rd.

A total of 166,827,660 gallons was recorded through customer meters. Some of the water losses are accounted for as follows:

- A. Main and Service leaks.**
- B. Hydrant Flushing**
- C. Highway use-street sweeping, drain and flushing**
- D. Fire Department use-2 million gallons**

**The repairs to the system were as follows.**

<b>Service Repairs</b>	<b>8</b>
<b>Water shutoff</b>	<b>7</b>
<b>Repaired hydrants</b>	<b>2</b>
<b>New meters</b>	<b>59</b>
<b>New auto readers</b>	<b>109</b>
<b>Water main breaks</b>	<b>5</b>

**The pumping stations are inspected daily and the meter readings are recorded. The storage tanks are inspected periodically.**

**The Massachusetts D.E.P. Is sent the results of water samples tested at the Microbac Laboratories Inc. 181 Cedar Hill St., Marlboro, Ma. On a monthly schedule. We can report that our water supply is in good condition.**

**The Boylston Water Water Commissioners meet each month on the first Monday, at 7:30pm at the Boylston Municipal Light Department located at 16 Paul Tivnan Dr., Boylston, Ma.**

Respectfully submitted,

Scott McCubrey Superintendent